

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/19/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155177		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 04 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/13/2012	
NAME OF PROVIDER OR SUPPLIER WESTMINSTER VILLAGE - WEST LAFAYETTE				STREET ADDRESS, CITY, STATE, ZIP CODE 2741 N SALISBURY ST WEST LAFAYETTE, IN 47906			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/30/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/13/12</p> <p>Facility Number: 000093 Provider Number: 155177 AIM Number: NA</p> <p>Surveyor: Bridget Brown, Life Safety Code Specialist</p> <p>At this PSR survey, Westminster Village-West Lafayette was found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The Courtyard was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility consisting of the Courtyard, Pavillion and Terrace was determined to be of Type III (211) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, resident rooms and spaces open to the corridors. The unoccupied Pavillion was undergoing demolition and renovation and was not surveyed. The facility has the capacity of 89 residents and had a census of 48 at the time of this survey.</p>			{K 000}			
{K 000}	INITIAL COMMENTS			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/19/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155177		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 04 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/13/2012	
NAME OF PROVIDER OR SUPPLIER WESTMINSTER VILLAGE - WEST LAFAYETTE				STREET ADDRESS, CITY, STATE, ZIP CODE 2741 N SALISBURY ST WEST LAFAYETTE, IN 47906			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>Continued From page 1</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/30/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/13/12</p> <p>Facility Number: 000093 Provider Number: 155177 AIM Number: NA</p> <p>Surveyor: Bridget Brown, Life Safety Code Specialist</p> <p>At this PSR survey, Westminster Village-West Lafayette was found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101 and 410 IAC 16.2. The Terrace was surveyed with Life Safety Code (LSC), Chapter 18, New Health Care Occupancies.</p> <p>The Terrace was located in a one story building determined to be of Type III (211) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, resident rooms and spaces open to the corridors. The unoccupied Pavillion was undergoing demolition and renovation and was not surveyed. The facility has the capacity of 89 residents and had a census of 48 at the time of this survey.</p>			{K 000}			